

# CERTIFICATE OF EMC

CERTIFICATE NO.: SET2015-01564

**Product:** Landing call and display interface board  
**Model:** BL2000-HXJ-V\* (\*=9-9.99, indicate the different customer or/and Software function number)  
**Applicant:** ShenYang Bluelight Automatic Technology Co., Ltd.  
**Address:** No. 37 Shiji Road, Hunnan New District, Shenyang, China

This is to certify that, on the basis of the tests undertaken as per Report No. SET2015-01564, the submitted sample of the above item complies with:

EN61000-6-4:2007+A1:2011  
EN61000-6-2:2005

and fulfils testing requirement of the EMC directive 2004/108/EC



Signed for and on behalf of  
**CCIC Southern Electronic Product Testing (Shenzhen) Co., Ltd.**

Wu Li An, Vice Director



Date of Issue: Feb. 06, 2015

**CCIC Southern Electronic Product Testing (Shenzhen) Co., Ltd.**  
 Building 28/29, Shigudong, Xixiang Industrial Area, Xili Street, Nanshan District,  
 Shenzhen, Guangdong, China  
 Tel: 86-755-26627338 Fax: 86-755-26627238 <http://www.ccic-set.com>



# EMC TEST REPORT

Report No. SET2015-01564

Product Landing call and display interface board

Model No BL2000-HXJ-V\* (\*=9-9.99, indicate the different customer or/and Software function number)

Applicant ShenYang Bluelight Automatic Technology Co., Ltd.

Address No. 37 Shiji Road, Hunnan New District, Shenyang, China

Issued by CCIC Southern Electronic Product Testing (Shenzhen)CO., Ltd.

Lab location Building 28/29, Shigudong, Xili Industrial Area, Xili Street, Nanshan District, Shenzhen, Guangdong, China

Tel 86 755 26627338 Fax 86 755 26627238



This test report consists of 23 pages in total and may be duplicated completely for legal use with the approval of the applicant. It should not be reproduced except in full, without the written approval of our laboratory. The client should not use it to claim product endorsement by CCIC-SET. The test results in the report only apply to the tested sample. The test report shall be invalid without all the signatures of testing engineer, reviewer and approver. Any objections must be raised to CCIC-SET within 15 days since the date when the report is received. It will not be taken into consideration beyond this limit.

查询码: 6PA7ZR5b

# Report

Product.....: Landing call and display interface board  
 Model No.....: BL2000-HXJ-V\* (\*=9-9.99, indicate the different customer or/and Software function number)  
 Brand Name.....: /  
 Applicant.....: ShenYang Bluelight Automatic Technology Co., Ltd.  
 Applicant Address.....: No. 37 Shiji Road, Hunnan New District, Shenyang, China  
 Manufacturer.....: ShenYang Bluelight Automatic Technology Co., Ltd.  
 Manufacturer Address.....: No. 37 Shiji Road, Hunnan New District, Shenyang, China  
 Test Standards.....: EN61000-6-4:2007+A1:2011 Electromagnetic compatibility (EMC) -- Part 6-4: Generic standards - Emission standard for industrial environments  
 EN61000-6-2:2005 Electromagnetic compatibility (EMC) -- Part 6-2: Generic standards - Immunity for industrial environments  
 Test Result.....: Pass  
 Tested by .....: \_\_\_\_\_ Feb. 06. 2015  
 Signature, Date  
 Reviewed by.....: \_\_\_\_\_ Feb. 06. 2015  
 Signature, Date  
 Approved by.....: *Wu Lian* Feb. 06. 2015  
 Signature, Date



## Table of Contents

Report.....	2
1 General Information .....	5
1.1 Description of EUT .....	5
1.2 Objective .....	
2 Test Facilities and Configuration .....	
2.1 Environmental Conditions .....	
2.2 Measurement Uncertainty .....	
2.3 Test Standards and Results .....	6
2.4 List of Equipments Used .....	7
3 Emission Test .....	8
3.1 EUT Setup and Operating Conditions .....	8
3.2 Radiated Disturbance Measurement .....	8
3.2.1 Limits of Radiated Disturbance .....	8
3.2.2 Test Setup .....	8
3.2.3 Test Result .....	9
4 Immunity Test .....	11
4.1 EUT Setup and Operating Conditions .....	11
4.2 Performance Criteria .....	11
4.3 Electrostatic Discharge Immunity Test .....	11
4.3.1 Test Specification .....	11
4.3.2 Test Setup .....	12
4.3.3 Test Result .....	12
4.4 Radiated, Radio Frequency Electromagnetic Field Immunity Test .....	13
4.4.1 Test Specification .....	13
4.4.2 Test Setup .....	13
4.4.3 Test Result .....	14



4.5 Electrical Fast Transient/Burst Immunity Test.....	14
4.5.1 Test Specification .....	14
4.5.2 Test Setup .....	14
4.5.3 Test Result .....	15
4.6 Surge Immunity Test .....	15
4.6.1 Test Specification .....	15
4.6.2 Test Setup .....	15
4.6.3 Test Result .....	15
4.7 Immunity to Conducted Disturbances Induced by RF Fields .....	16
4.7.1 Test Specification .....	16
4.7.2 Test Setup .....	16
4.7.3 Test Result .....	16
4.8 Power Frequency Magnetic Field Immunity Test .....	17
4.8.1 Test Specification .....	17
4.8.2 Test Setup .....	17
4.8.3 Test Result .....	17
Appendix I Photographs of the EUT .....	18
Appendix II Photographs of EMC Test Configuration .....	19

# 1 General Information

## 1.1 Description of EUT

Product: Landing call and display interface board  
 Model No.: BL2000-HXJ-V9  
 Brand Name: /  
 Serial No.: /  
 Rating: Input: 24V DC  
 Accessories: /

### NOTE:

1. For more detailed features description about EUT, please refer to User's Manual.
2. Application model is BL2000-HXJ-V\* (\*=9-9.99 indicate the different customer or/and Software function number). Models differences do not affect the performance of EMC. All tests were performed on Model BL2000-HXJ-V9 and results represented other models.
3. The highest frequency of the internal source of EUT is below 108 MHz, so the radiated emission measurement shall be made up to 1GHz.

## 1.2 Objective

Perform ElectroMagnetic Interference (EMI) and ElectroMagnetic Susceptibility (EMS) tests for CE Marking.

# 2 Test Facilities and Configuration

## 2.1 Environmental Conditions

During the measurement the environmental conditions were within the listed ranges:

- Temperature: 15-35°C
- Humidity: 30-60 %
- Atmospheric pressure: 86-106 kPa

## 2.2 Measurement Uncertainty

The uncertainty is calculated using the methods suggested in the "Guide to the Expression of Uncertainty in Measurement" (GUM) published by ISO.

- Uncertainty of Radiated Emission,  $U_c = \pm 4.7\text{dB}$

## 2.3 Test Standards and Results

The EUT has been tested according to the following specifications:

EMISSION		
Standard	Test Type	Result
EN61000-6-4:2007+A1:2011	Radiated disturbance	PASS
IMMUNITY (EN61000-6-2:2005)		
Basic Standard	Test Type	Result
IEC 61000-4-2	Electrostatic discharge immunity	PASS
IEC 61000-4-3	Radiated, radio frequency electromagnetic field immunity	PASS
IEC 61000-4-4	Electrical fast transient/burst immunity	PASS
IEC 61000-4-5	Surge immunity	PASS
IEC 61000-4-6	Immunity to conducted disturbances induced by RF fields	PASS
IEC 61000-4-8	Power frequency magnetic field immunity	PASS

## 2.4 List of Equipments Used

Description	Manufacturer	Model No.	Calibration Date	Serial No.
Test Receiver	ROHDE&SCHWARZ	ESCI	Jun.10, 2015	A0902601
Broadband Ant.	ROHDE&SCHWARZ	VULB 09160	Jun.10, 2015	A08055
Anechoic Chamber	Albatross	SAC-10MAC 19.6*11.8*8.55m	Jun.23, 2015	A0802520
Signal Generator	ROHDE&SCHWARZ	SMR27	Jun.10, 2015	A0304
Signal Generator	ROHDE&SCHWARZ	SML02	Jun.10, 2015	A0304
EMS Antenna	Amplifier Research	AR AT1080	Jun.10, 2015	A0304
EMS Antenna	Amplifier Research	AR AT4002A	Jun.10, 2015	A0304250
Power Amplifier	Amplifier Research	150W1000	/	A0304247
Power Amplifier	Amplifier Research	AR 75A250M	/	A0304255
Power Amplifier	Amplifier Research	25S1g4AM1	/	A0304248
Capacitive clamp	ROHDE&SCHWARZ	F2301	/	A0304258
EFT Test System	HAEFELY	PEFT JUNIOR	May.22, 2015	A0103110
Surge Test System	EM TEST	VCS500M10	Jun.10, 2015	A0712509
	EM TEST	CNV503S9	Jun.10, 2015	A0712510
ESD Test System	EM TEST	ESD30C	Sep.24.2015	A0712513
Magnetic Field Tester	HAEFELY	MAG 100.1	Jun.10. 2015	A0103109

NOTE: Equipments above have been calibrated and are in the period of validation.

### 3 Emission Test

#### 3.1 EUT Setup and Operating Conditions

The EUT was powered by 24V DC mains. The EUT was continuously operated during the test.

#### 3.2 Radiated Disturbance Measurement

##### 3.2.1 Limits of Radiated Disturbance

Frequency range (MHz)	Quasi peak limits(dB $\mu$ V/m), at 10m measurement distance
30 – 230	40
230 - 1000	47

Notes:

- (1) The lower limit shall apply at the transition frequency.
- (2) Additional provisions may be required for cases where interference occurs.

##### 3.2.2 Test Setup

### 3.2.3 Test Result

No.	Frequency
-----	-----------



1. Electromagnetic radiation disturbances, max detector, antenna polarization: Vertical

2. Electromagnetic radiation disturbances, max peak detector, antenna polarization: Horizontal



## 4 Immunity Test

### 4.1 EUT Setup and Operating Conditions

Same as 3.1.

### 4.2 Performance Criteria


Criterion A	The apparatus shall continue to operate as intended. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the apparatus is used as intended.
Criterion B	The apparatus shall continue to operate as intended after the test. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the apparatus is used as intended.
Criterion C	Temporary loss of function is allowed, provided the function is self-recoverable or can be restored by the operation of the controls.

### 4.3 Electrostatic Discharge Immunity Test

#### 4.3.1 Test Specification

Basic Standard:	IEC 61000-4-2
Discharge Impedance	330 $\Omega$ / 150 pF
Discharge Voltage:	Air Discharge: 8 kV Contact Discharge: 4kV
Polarity:	Positive / Negative
Number of Discharge:	Minimum 20 times at each test point
Discharge Mode:	Single discharge
Discharge Period:	1-second minimum
Criterion:	B

### 4.3.2 Test Setup



For the actual test configuration, please refer to Appendix D Photographs of the Test Configuration.

### 4.3.3 Test Result

Test Points	Discharge Level (kV)	Discharge Mode	Observation	Comply with Criterion
Screen	±2, 4, 6, 8	Air	Note(1)	A
HCP	f 2, 4	Contact	Note(1)	A
VCP	f 2, 4	Contact	Note(1)	A

NOTE:


(1). The EUT continued to operate as intended. No degradation of performance was observed.

## 4.4 Radiated, Radio Frequency Electromagnetic Field Immunity Test

### 4.4.1 Test Specification

Basic Standard:	EN 61000-4-3		
Frequency Range:	80 MHz – 1000MHz	1.4GHz – 2.0GHz	2.0GHz – 2.7GHz
Field Strength:	10V/m	3V/m	1V/m
Modulation:	1kHz sine wave, 80%, AM modulation		
Frequency Step:	1% of fundamental		
Polarity of Antenna	Horizontal and Vertical		
Test Distance:	3m		
Antenna Height:	1.5m		
Dwell Time:	3 seconds		
Criterion:	A		

### 4.4.2 Test Setup



### 4.4.3 Test Result

Frequency	Polarity	Azimuth	Field Strength (V/m)	Observation	Comply with Criterion
80-1000 MHz	V&H	0,90, 80, 270	10	Note(1)	A
1.4-2.0GHz	V&H	0,90, 80, 270	3	Note(1)	A
2.0-2.7GHz	V&H	0,90, 80, 270	1	Note(1)	A

NOTE:


(1). The EUT continued to operate as intended. No degradation of performance was observed.

### 4.5 Electrical Fast Transient/Burst Immunity Test

#### 4.5.1 Test Specification

Basic Standard:	IEC 61000-4-4
Test Voltage:	DC. Power port: 2 kV, Signal port: 1 kV
Polarity:	Positive/Negative
Impulse Frequency:	5kHz
Impulse wave shape:	5/50ns
Burst Duration:	15ms
Burst Period:	300ms
Test Duration:	Not less than 1 min.
Criterion:	B

#### 4.5.2 Test Setup



For the actual test configuration, please refer to Appendix D Photographs of the Test Configuration.

### 4.5.3 Test Result

Test Point	Polarity	Test Level (kV)	Observation	Comply with Criterion
DC. power	+/-	2	Note (1)	A
Signal port	+/-	1	Note (1)	A

NOTE:


(1). The EUT continued to operate as intended. No degradation of performance was observed.

### 4.6 Surge Immunity Test

#### 4.6.1 Test Specification

Basic Standard:	IEC 61000-4-5
Waveform:	Voltage 1.2/50µs; Current 8/20µs
Test Voltage:	DC power port: line to line 0.5 kV, line to earth 0.5 kV
Polarity:	Positive/Negative
Repetition Rate:	60sec
Times:	5 time/each condition.
Criterion:	B

#### 4.6.2 Test Setup



#### 4.6.3 Test Result

Coupling Line	Polarity	Voltage (kV)	Observation	Comply with Criterion
DC power, Line-Line	+/-	0.5	Note (1)	B

NOTE:

(1). The EUT continued to operate as intended. No degradation of performance was observed.



## 4.7 Immunity to Conducted Disturbances Induced by RF Fields

### 4.7.1 Test Specification

Basic Standard:	IEC 61000-4-6
Frequency Range:	0.15 MHz – 80 MHz
Field Strength:	10V
Modulation:	1 kHz Sine Wave, 80%, AM Modulation




## 4.8 Power Frequency Magnetic Field Immunity Test

### 4.8.1 Test Specification

Basic Standard:	IEC 61000-4-8
Frequency Range:	50Hz




# Appendix I Photographs of the EUT



## Appendix II Photographs of EMC Test Configuration

### 1. Radiated Field Strength Measurement

### 2. Electrostatic Discharge Immunity Test




3. Radiated, Radio Frequency Electromagnetic Field Immunity Test (below 1GHz)

4. Radiated, Radio Frequency Electromagnetic Field Immunity Test (above 1GHz)




5. Electrical Fast Transient/Burst Immunity Test

6. Surge Immunity Test



7. Immunity to Conducted Disturbances Induced by RF Fields

8. Power Frequency magnetic Field Immunity



# STATEMENT

This test laboratory is accredited by CNAS, Accreditation Certificate No. L1659.

2. The test report is invalid without stamp of laboratory.
3. The test report is invalid without signature of person(s) testing and authorizing.
4. The test report is invalid if erased and corrected.
5. Test results of the report is valid to the test samples if sampling by client.
6.  item cannot be Accredited by CNAS.
7. The test report shall not be reproduced except in full, without written approval of the laboratory.
8. If there is any objection to report, the client should inform issuing laboratory within 15 days from the date of receiving test report.

Address: Building 28/29, Shigudong, Xili Industrial Area, Xili Street, Nanshan District, Shenzhen, Guangdong, China  
P.C. 518055

TEL 0755-26628093/26627338

FAX 0755-26627238

Internet <http://www.ccic-set.com>

E-Mail [manager@ccic-set.com](mailto:manager@ccic-set.com)